

Integrated Utility Management for Large Campuses: A Digital Framework for Reliability Improvement and Energy Conservation

RAJENDRA PRASAD N¹, SRILATHA KALVACHERLA²

^{1, 2}*Electrical maintenance Division /IPS, Indian Institute of Technology Bombay, Mumbai, India*

Abstract- Large institutional campuses — academic, research, industrial and township — behave as small cities, aggregating electrical distribution, water supply and pumping, HVAC, fire protection, security, transportation, medical facilities and, increasingly, communication networks and data centers into a single operational envelope managed by one engineering division. Energy efficiency, digitalization and reliability are conventionally pursued as separate initiatives, with energy decisions taken in isolation from condition data and breakdown-driven maintenance generating no measurable performance record. This paper presents an integrated framework in which energy efficiency, digitalization and reliability enhancement are treated as three mutually reinforcing objectives coupled to a single data backbone, so that efficiency gains are measured rather than assumed and reliability improvement is verified rather than asserted. Digitalization is realised through a five-layer architecture — sensing and instrumentation, communication, a supervisory platform (SCADA, BMS and IoT), analytics and alerting, and strategic planning — from which a condition-based maintenance regime and building-wise energy accounting are both derived. Energy efficiency is pursued through a three-principle framework — Awareness, Optimize and Generate — extended to renewable generation through rooftop solar, open-access procurement and battery energy storage. The framework is demonstrated through a quantified case study of an institutional campus covering pumping automation and central utility monitoring, reporting baseline-to-post-implementation figures for energy consumption, reliability indices and monitored asset coverage, and is set out as a phased sustainability roadmap so that other institutions can plan a comparable transition. Expected outcomes include verified reduction in specific energy consumption, measurable improvement in system availability, creation of equipment history for capacity planning, and a credible, quantified pathway to a high renewable-energy share.

Index Terms—Energy efficiency, digitalization, reliability enhancement, institutional campus, quantified case study, sustainability roadmap, battery energy storage, condition-

based maintenance, energy management, IoT, open access, renewable energy, SCADA.

I. INTRODUCTION

A large campus or a planned community accommodates residential, academic, research, industrial, medical and administrative facilities within a common boundary and under a common engineering administration. For the population served, the distinction between a utility and a service disappears: an interruption of water supply, a failure of the air-conditioning plant in a laboratory, or the loss of a network link to a data center are all experienced as a failure of the campus itself. Ensuring uninterrupted supply and service availability is therefore a matter of public interest and not merely of departmental performance.

Utility services of such a community can be grouped into essential and supporting categories. The conventional essential set comprises electricity, water supply, fire protection, security, medical services and transportation. With the digitization of banking, education, research and industrial activity, communication networks, internet connectivity and data center services have become equally critical; a modern campus cannot meet its performance indicators if these fail, even when all conventional utilities are available. Table I summarizes this classification.

Among these, electricity is the primary and most pervasive requirement. Lighting, air circulation, HVAC, water pumping, networking, data centers, laboratory loads and industrial processes are all electrically driven, and electricity is critical across its entire chain — generation, transmission, distribution,

utilization, and the safety of both the user and the equipment. Electricity also directly determines the carbon footprint and a large fraction of the recurring operating cost of the campus. Four areas consequently demand sustained engineering attention in any campus electrical distribution network:

- 1) Effective planning of capacities and upgradations;
- 2) Safe and reliable operation;
- 3) Monitoring and control;
- 4) Energy conservation.

These four are frequently pursued by separate groups using separate records. The central argument of this paper is that reliability, monitoring, control, upgradation and planning are interrelated and jointly define system capability and effectiveness, and therefore cannot be treated separately. A monitoring scheme that does not feed maintenance planning produces data without decisions; a maintenance plan without condition data produces intervention without evidence; an energy conservation programme without metering produces claims without verification; and capacity planning without load history produces either stranded assets or constrained growth.

This paper accordingly proposes an integrated utility management model with three coupled objectives — digitization, reliability improvement and energy conservation — and sets out a road map by which a public or industrial community can move from a breakdown-driven regime to a data-driven one. The remainder of the paper is organised as follows. Section II describes the utility landscape of a large campus. Section III presents the proposed integrated model.

Section IV develops the reliability-centered operations and maintenance regime. Section V presents the energy conservation framework. Section VI specifies the digitization and automation architecture. Section VII gives the implementation road map. Section VIII presents two case studies. Section IX defines expected outcomes and key performance indicators, Section X discusses limitations, and Section XI concludes.

II. PROBLEM DEFINITION AND DESIGN REQUIREMENTS

1. UTILITY LANDSCAPE OF A LARGE CAMPUS

A. Classification of Campus Utilities:

Utility management typically evolves in layers. Electrical distribution, pumps, HVAC systems, generators, fire systems, and other assets may have their own operators, controllers, maintenance schedules, and records. Such specialization is necessary, but the resulting information silos can limit system-level decisions. A utility outage, for example, can have consequences for water pumping, HVAC, laboratories, communication systems, and occupant services. Similarly, an inefficient pump or cooling plant can create both reliability and energy consequences.

Table I classifies campus utilities by criticality and by the tolerable interruption duration typically accepted by the user community. The tolerable duration is an operational planning input: it determines whether a service requires redundancy at the source, at the distribution level, or not at all, and it determines the response-time target for the maintenance organization.

TABLE I. CLASSIFICATION OF CAMPUS UTILITIES AND SERVICE CRITICALITY

Utility / service	Principal dependency	Typical tolerable interruption
Electricity	Grid supply, HT/LT distribution, DG, UPS	Seconds to minutes
Water supply	Source, pumping, storage, distribution — electrically driven	Hours
Fire protection	Hydrant and sprinkler pumps, detection, alarm	Zero (standby must be continuous)

Utility / service	Principal dependency	Typical tolerable interruption
Security / CCTV	Power, network, recording infrastructure	Minutes
Medical services	Power, HVAC, water, medical gases	Zero for critical areas
Transportation	Roads, lighting, fleet, charging infrastructure	Hours
HVAC	Chillers, AHUs, VRF, cooling water	Minutes to hours by area
Communication, internet, data centre	Power, precision cooling, redundant links	Seconds

B. Interdependence of Utilities

The classification above conceals a stronger property: the utilities are not parallel services but a dependency graph rooted in electricity. Water supply depends on pumping, which depends on electricity. Fire protection depends on jockey and main pumps, which depend on electricity and on the reliability of their starters. Security and communication depend on both electricity and cooling. Cooling depends on electricity and on the availability of cooling water. A single distribution-level event therefore propagates into several services simultaneously, and the perceived severity of an electrical fault is far greater than its electrical magnitude alone would suggest.

This interdependence has two consequences for management. First, reliability investment in the

electrical system yields compounded returns across all dependent services, which justifies treating electrical reliability as the primary lever. Second, monitoring must be integrated across utilities: an alarm on a pumping station and an alarm on the feeder supplying it are the same event observed twice, and an integrated platform can correlate them where two isolated systems cannot.

C. The proposed model therefore uses five design requirements: (1) continuity and safety of critical services; (2) visibility of equipment condition and operating parameters; (3) structured maintenance and asset history; (4) measurable energy performance; and (5) a feedback mechanism from operational data to capital and lifecycle planning.

Table II. Design requirements of the integrated utility management model.

Requirement	Management Question	Digital/Operational Response
Service continuity	What must remain available?	Criticality classification, redundancy, alarms, contingency plans
Asset reliability	What condition is the asset in?	Condition monitoring, PM/CBM, trends, history cards
Operational control	What is happening now?	SCADA/BMS/IoT, remote status and control
Energy performance	Where and why is energy used?	Submetering, load profiles, KPIs, optimization
Lifecycle planning	What should be upgraded and when?	Asset health, risk, capacity and cost analysis

III. INTEGRATED UTILITY MANAGEMENT FRAMEWORK

The proposed framework is organized as a closed management loop rather than a linear project. At the

base are utility assets and users. Above them are operations and maintenance processes. Digitization provides continuous data acquisition and control. Analytics convert data into condition, performance, and energy information. Management decisions then

determine maintenance, optimization, replacement, and capacity actions. The outcomes are fed back into the system through updated operating limits, maintenance plans, budgets, and asset strategies.

The framework can be represented as:

Campus Utilities → Operations & Maintenance → Digitization → Analytics & Alerts → Reliability/Energy Decisions → Lifecycle Planning → Continuous Improvement

A. Utility Operations

Operations include load monitoring, load sharing or shifting, planned shutdowns, maintenance scheduling, safety controls, checklists, operating procedures, and emergency response. The source material emphasizes regular load monitoring and recording of critical parameters as a foundation for analysis.

B. Reliability-Centered Maintenance

The model combines preventive maintenance (PM) with predictive or condition-based maintenance (CBM). Preventive maintenance remains necessary for statutory, safety, lubrication, inspection, testing, and known-life activities. However, fixed intervals alone may not detect early deterioration and can lead to replacement of components that remain serviceable. Condition-based maintenance addresses this limitation by using measured parameters and data trends to identify deterioration.

A practical hierarchy is therefore proposed: statutory maintenance → preventive maintenance → condition monitoring → predictive diagnostics → risk-based intervention. The maturity level can differ by asset criticality and data availability.

C. Digital Utility Layer

The digital layer collects parameters such as pressure, temperature, flow, humidity, current, voltage, power factor, breaker status, energy consumption, and running hours. Thresholds can be configured to generate real-time alarms. SCADA, BMS, and IoT platforms can provide the communications and visualization layer, while sensors, transducers, switches, and actuators connect field equipment to the digital system.

For a large campus, the architecture should not require every system to be replaced simultaneously. A federated approach is more practical: retain existing PLCs, meters, protection relays, BMS and controllers where appropriate; add gateways and standardized data interfaces; and bring the resulting information into a common monitoring layer.

D. Data-to-Decision Layer

The value of digitization is not the dashboard itself. Data must lead to an operational or management action. A useful event chain is: measurement → validation → threshold/trend detection → alarm → acknowledgement → work order or operating action → closure → history update → KPI review. This creates a traceable relationship between field condition and management decision.


III. RELIABILITY-CENTERED OPERATIONS AND MAINTENANCE

A.Reliability, monitoring, control, upgradation, and planning are interrelated. The source framework describes them as a connected system capability rather than independent activities. This paper extends that concept by treating the campus as a portfolio of assets with different criticalities, failure consequences, operating profiles, and lifecycle costs.

Table III. Example condition-monitoring parameters for campus utility assets.

Asset Class	Indicative Parameters	Decision Trigger
Electrical distribution	V, I, kW, PF, temperature, breaker status	Overload, abnormal temperature, protection/alarm
Pumps	Flow, pressure, current, run hours, level	Low flow, high current, overflow risk, poor efficiency

HVAC	Supply/return temperature, pressure, status, energy	Temperature deviation, abnormal energy, equipment fault
DG systems	Run hours, load, fuel/energy, alarms	Excessive runtime, alarm, abnormal consumption
Water systems	Tank level, flow, pressure, pump status	Low level, overflow, leakage, pump abnormality



Pic.1 Reliability cycle

B. Maintenance

Maintenance is an important but unglamorous function, and it is habitually given lower priority than the production or academic output of the organization. Over the past two to three decades, however, the view of maintenance has been observed to change, and methodologies other than conventional breakdown maintenance have been adopted. Quality and asset

management systems such as Six Sigma, Total Productive Maintenance, and the ISO family encourage preventive, predictive and condition-based maintenance by making explicit the necessity of maintenance planning and the cost of unplanned production outages and safety breaches.

Table IV compares the four maintenance regimes on the criteria that matter for campus utilities.

Regime	Trigger	Data need	Outage risk	Principal limitation
Breakdown	Failure	None	High	Unplanned outage, consequential damage, safety exposure
Preventive (time based)	Calendar or running hours	History card, OEM manual	Medium	Early deterioration invisible; healthy components replaced
Predictive / condition based	Parameter deviation	Trended condition parameters	Low	Requires instrumentation and analysis competence
Digitized condition monitoring	Automated alert on deviation	Continuous sensed data	Lowest	Capital cost, integration and cybersecurity effort

1) Preventive maintenance plan

A preventive maintenance plan can avert the occurrence of breakdowns and improve safe equipment operation by planning shutdowns and by reconditioning or servicing long-running equipment. Scheduling and the definition of test and restoration parameters are central to it. The history card of the equipment, the recommendations of the original equipment manufacturer, and information from operations and users together allow effective checkpoints to be established.

The method has two well-recognized limitations. First, deterioration that begins between two scheduled interventions cannot be detected, so a fault that develops early in an interval progresses unobserved until the next visit or until failure. Second, the replacement of defined components at defined intervals necessarily discards healthy components and consumables, which is both a cost and, in a sustainability context, a material concern.

2) Predictive and condition-based maintenance

A further advance is condition-based maintenance. Instead of depending on a predefined schedule, a systematic condition monitoring scheme is prepared containing the critical system parameters that define the functioning and efficiency of the equipment. These parameters are observed at regular intervals and trended over time, and intervention is triggered by the trend rather than by the calendar.

Typical condition parameters for campus utility assets include winding and oil temperature and dissolved gas content for transformers; contact resistance, operating time and mechanism condition for circuit breakers; insulation resistance, polarization index and partial discharge activity for cables and switchgear; vibration signature, bearing temperature, current signature and efficiency at duty point for motors and pumps; and approach temperature, pressure differential and specific power consumption for chillers.

For further advancement, machine-based and automated monitoring should be preferred over manual data collection, for accuracy, for frequency of sampling, and because a manual regime degrades

under workload pressure precisely when the plant is most stressed.

C. Reliability Measurement

A reliability-centered model requires reliability to be measured rather than asserted. At the equipment level, mean time between failures, mean time to repair and availability are computed from the maintenance record. At the distribution level, interruption indices such as SAIFI, SAIDI and CAIDI, defined for distribution systems in, can be adapted to campus feeders and to individual buildings by treating each building service connection as a customer. These measures make the effect of an intervention visible and convert reliability from a qualitative claim into a reported quantity.

D. Asset management

Asset management principles can provide the governance layer for this approach. ISO 55000:2024 establishes asset-management vocabulary, overview, and principles, while ISO 55001:2024 specifies requirements for an asset-management system. The 2024 revision places additional emphasis on decision-making, resources, data and information, and predictive action, which are directly relevant to a data-enabled utility management model.

A campus implementation should therefore maintain a minimum digital asset record for critical equipment: unique asset identifier, location, make/model, rating, installation date, criticality, maintenance history, failure history, operating parameters, statutory records, spare strategy, and replacement/upgrade status.

IV. ENERGY CONSERVATION FRAMEWORK

With rising power demand in society and industry, energy conservation is not only a necessity but a responsibility of every entity and every individual. The framework adopted here rests on three basic principles — Awareness, Optimize and Generate — applied in that order, because behavioral measures require no capital, efficiency measures require moderate capital with short payback, and generation

requires the largest commitment and is most effective once demand has already been reduced.

A. Awareness

Awareness is created among the user community by various means, beginning with the implementation of minor tasks whose effect is visible to the user:

- Lights are not switched on during daylight hours in adequately day-lit spaces.
- Cooling and heating are optimised rather than maximised.
- Water is not wasted and leakages are not tolerated, since every leak triggers pumping and therefore electricity consumption.
- Responsibility for common utilities is accepted by occupants and not assigned solely to the maintenance division.
- A considered choice is made between elevator and staircase for short vertical movements.

- Public and shared transport options are preferred within and to the campus.

The effectiveness of awareness campaigns is difficult to sustain without feedback. Publishing building-wise consumption obtained from the remote metering described in Section V converts a general appeal into a comparison between peer buildings, which is materially more effective and which costs nothing once metering exists.

B. Optimize

Energy is reduced by the deployment of efficient appliances and by optimization of the operating regime. The principal measures applicable to a campus are summarized in Table III.

TABLE III. ENERGY EFFICIENCY MEASURES, INDICATIVE SAVINGS AND PAYBACK

Measure	Replaces	Indicative saving	Indicative payback
LED luminaires	Conventional and CFL lighting	About 40 %	Under 4 years
BLDC ceiling fans	Induction-motor ceiling fans	About 55 %	Under 2 years
Inverter-based cooling systems	Fixed-speed room air conditioners	Site specific	Site specific
VRF systems for grouped air conditioning	Multiple standalone units	Site specific	Site specific
District cooling / common cooling plant for multiple facilities	Distributed independent plants	Site specific	Site specific
Temperature set-point optimization	Uncontrolled set points	Site specific	Immediate
Pump scheduling and level-based automation	Manual pump operation	Site specific	Site specific

The savings and payback figures in Table III are indicative values for planning purposes. Actual values depend on tariff, operating hours, ambient conditions and the baseline equipment being displaced, and should be established by measurement before and after implementation. The metering infrastructure described in Section V is what makes such verification possible; without it, savings remain estimates. Measurement and verification should follow the organization's energy management system procedures [6].

C. Generate: Renewable Energy

Generating part of the power consumed by the community is both a need and a responsibility, and increasing the renewable component of campus consumption is among the most visible actions an institution can take.

1) Rooftop and in-house solar generation

The first step is to identify rooftops and unused spaces suitable for solar generation, allowing for shading, structural capacity, and future building plans. A

suitable commercial model is then worked out, typically CAPEX, in which the institution owns the asset, or RESCO, in which a developer owns and operates it and the institution purchases the generated energy. A billing model must be created and the maintenance of the system — particularly module cleaning, string monitoring and inverter servicing — must be assured, since soiling and undetected string failures are the usual causes of underperformance.

However, rooftop and in-house solar alone cannot completely meet the power requirement of a large campus. The available roof area is bounded by the

built-up footprint, and generation is limited to daylight hours. Something larger is required to supply green power to the campus at a high or complete share.

2) Open access procurement with storage

The solution proposed for a net-zero pathway is open-access procurement of solar or wind power, combined with battery energy storage to address the temporal mismatch between generation and campus load. The option is widely available in several models in the market. Three principal models are compared in Table IV.

TABLE IV. OPEN ACCESS PROCUREMENT MODELS

Model	User investment	Advantages	Considerations
Captive	100 % by user	Lowest long-run energy cost; full control of the asset	Large capital outlay; user carries performance and O&M risk
Group captive	Minimum 26 % by user; balance by RESCO	Balances tariff benefit against capital commitment	Equity and consumption share conditions must be maintained continuously
RESCO	Nil; 100 % by RESCO	No capital outlay; performance risk with developer	Higher unit tariff; long-term contractual lock-in

The choice among these models is governed less by engineering than by the capital availability, risk appetite and procurement rules of the institution, and by the prevailing regulatory position on open access charges, banking and cross-subsidy surcharge, which varies by state and changes over time. The engineering contribution is to establish the load profile, the firm and flexible components of demand, and the storage capacity required to achieve the targeted renewable share — all of which are derived from the metering and monitoring infrastructure described in Section VI.

V. DIGITIZATION AND AUTOMATION

In addition to preventive and predictive maintenance, current technological change creates both the possibility and the necessity of digitization in maintenance and system condition monitoring. Digitization provides the opportunity to monitor and record real-time equipment data continuously, which is the enabling condition for condition-based maintenance at campus scale. A scalable architecture separates field control from enterprise-level monitoring; the proposed model uses the four layers in Table IV.

TABLE IV. PROPOSED FOUR-LAYER DIGITAL UTILITY ARCHITECTURE

Layer	Typical Components	Primary Function
L1 — Field	Sensors, meters, switches, actuators	Measure physical condition and consumption
L2 — Control	PLC, RTU, protection relay, local controller	Local logic, interlocks, protection and control

Layer	Typical Components	Primary Function
L3 — Supervisory	SCADA, BMS, IoT gateway, historian	Visualization, alarms, trends and supervisory control
L4 — Management	Dashboard, CMMS/EAM, analytics, reports	Work orders, KPIs, lifecycle and strategic decisions

A. Sensing and Parameter Definition

Pressure, temperature, flow, humidity, current, voltage, power factor, breaker position, energy consumption, running hours, and other values are acquired at L1. For each parameter, a minimum and maximum admissible range is defined so that real-time alerts are raised on any deviation. Defining these ranges is an engineering task, not a configuration task: ranges set too wide suppress useful alarms, and ranges set too narrow cause alarm flooding, after which operators begin to ignore the system. An alarm rationalisation review after the first months of operation should be planned from the outset.

B. Platforms and Field Devices

L2 and L3 are implemented through SCADA, BMS, and IoT-based platforms, using transducers, sensors, flow switches, level switches, and actuators. In practice the three coexist: SCADA supervises the substation and electrical distribution network; BMS supervises HVAC, lighting, and building services; and IoT gateways extend coverage to distributed assets — remote pumping stations, overhead tanks, street-lighting feeder pillars, standalone meters — for which dedicated cabling would be uneconomic.

C. Communication and Interoperability

Interoperability determines whether these layers can be integrated later or must be replaced. Substation automation is conveniently standardised on IEC 61850; building services commonly use BACnet or Modbus; and distributed IoT assets typically use MQTT over cellular, LoRaWAN, or campus Wi-Fi. Open, documented protocols should be specified at the procurement stage: a proprietary protocol adopted for a single subsystem becomes the principal obstacle to central monitoring three to five years later. A campus inevitably contains equipment from multiple OEMs and generations, so the integration strategy should

prioritise standard protocols and gateway-based interoperability where technically and commercially appropriate, while preserving safety interlocks and manufacturer requirements.

D. Analytics, Alerts and History (L4)

The analytics layer performs four functions: exception detection against defined ranges; trending of condition parameters to support predictive intervention; automatic construction of equipment history cards — running hours, operations counted, alarms raised, work executed; and generation of periodic reports for management. The automatic history card is the single feature with the greatest long-term value, as it removes the dependence of institutional memory on individual personnel.

E. Cybersecurity and Resilience

Connecting operational technology to campus networks introduces exposure that did not exist in isolated systems. Segmentation of the operational technology network from the administrative network, role-based access, controlled remote access, backup and recovery, audit trails, time synchronisation, configuration management, and secure change control should be included according to the criticality of each system, in accordance with the industrial automation security framework. Digital control should also fail safely: every automated system must remain operable in local manual mode, so that loss of the supervisory layer degrades visibility but does not disable essential local protection or interrupt the utility.

F. Performance Measurement and Decision Support

An integrated system requires a small set of actionable KPIs. The purpose is not to maximize the number of dashboard indicators but to connect measurements to service outcomes.

Table IV. Suggested KPI structure for integrated utility management.

Dimension	Suggested KPI	Use
Reliability	Availability; outage frequency; MTBF; MTTR	Assess continuity and maintenance effectiveness
Maintenance	PM compliance; CBM coverage; repeat failures	Measure maintenance maturity
Energy	kWh/m ² ; kWh/unit output; peak demand; PF	Identify efficiency and demand opportunities
Water	kL/day; kL/user; pump energy per kL	Track water and pumping efficiency
Digital	Asset coverage; alarm response; data quality	Measure digital adoption and usefulness
Planning	Risk-ranked renewal backlog; capacity headroom	Prioritize CAPEX and upgrades

For energy projects, the preferred evaluation method is a measured baseline followed by normalized comparison with the post-implementation period. Where operating conditions vary, the analysis should account for relevant drivers such as occupancy,

weather, production, operating hours, and process demand. For reliability projects, failure and interruption data should be recorded consistently before and after intervention.




Fig. 1 Four-Layer Architecture and L2-L3 Protocols

VI. IMPLEMENTATION ROADMAP

This section sets out the phased roadmap by which an institutional campus can move from the current baseline to the target state of energy efficiency, digitalization and reliability described in Sections IV

to VI, with indicative timelines, prerequisites, deliverables and quantified targets for each phase.


The roadmap should translate the framework into a staged program. The source material identifies the need for an implementation roadmap with timelines

and focused actions for public or industrial communities.

implement targeted energy measures, and then use the accumulated data for lifecycle and strategic planning.

A practical sequence is to establish the baseline first, digitize high-criticality assets, integrate monitoring,

Phase	Indicative period	Main actions	Primary output / KPI
0—Baseline	Before implementation	Asset register, SLD verification, load/energy baseline, failure history	Verified baseline and criticality register
1—Foundation	0–6 months	PM plan, checklists, history cards, safety procedures, awareness	PM compliance and documented asset history
2—Instrumentation	6–18 months	SCADA, remote metering, pumping, HVAC and DG monitoring	Online coverage and data availability
3—Integration	18–30 months	Central monitoring, alarm rationalization, CBM triggers, cybersecurity	Alarm-to-action ratio and CBM coverage
4—Optimization	24–36 months	Efficiency retrofits, set-point/scheduling optimization, M&V	Verified energy savings
5—Generation	30–60 months	Rooftop solar, open access, BESS	Renewable share and storage utilization



VII. CASE STUDIES

Two case studies are presented to illustrate the implementation of the proposed model. The first addresses reliability improvement and energy conservation in the campus pumping system through automation. The second addresses the creation of a central utility monitoring and control facility spanning several utility systems.

A. Case Study I: Campus Pumping Automation: Smart Pumping System Retrofit: An Integrated Reliability, Energy Saving and Digitalization Case Study

This case study covers the application of the strategy to the pumping area, at two levels: automation of the main pumping station, and local or area-level pumping

automation for energy conservation and mitigation of overflow.

1. Case Study Overview

An institutional pumping system consisting of three conventional 150 kW pump-motor sets (450 kW total) was operated through manual ON/OFF control with limited operational feedback and no online condition

monitoring. The proposed retrofit integrates three 40 kW IE5 pump-motor sets, VFD-based pressure control, online electrical/hydraulic monitoring and Condition-Based Maintenance (CBM). The intervention therefore addresses three objectives simultaneously: improving reliability, reducing energy consumption and enabling digital utility management.

2. Integrated Transformation

Focus Area	Existing Condition	Proposed Smart System	Expected Improvement
Reliability	Manual operation; limited feedback; breakdown-oriented maintenance	Continuous parameter monitoring, alarms, CBM and standby management	Early fault detection, improved availability and planned maintenance
Energy Saving	3 × 150 kW fixed-speed motors; operation not matched to demand	3 × 40 kW IE5 motors with VFD and pressure feedback	Demand-based pumping and reduced unnecessary energy consumption
Digitization	No online electrical/hydraulic monitoring	Sensors → PLC → BMS/SCADA → dashboard/analytics	Real-time visibility, trend analysis and data-driven decisions

3. Reliability Enhancement

The principal reliability improvement is the transition from reactive/preventive maintenance to condition-based maintenance. Motor current, voltage, kW, discharge pressure, flow, pump status and VFD faults are continuously monitored. Alarm thresholds and trend analysis enable abnormal operating conditions to be identified before they develop into major failures.

The system can identify conditions such as increasing power for the same hydraulic output, pressure deviation, flow deterioration, repeated VFD trips and excessive pump starts. These trends can indicate hydraulic deterioration, impeller wear, mechanical problems, increased system resistance or motor/VFD abnormalities, allowing maintenance to be planned based on actual equipment condition.

Reliability KPIs: MTBF, MTTR, equipment availability, breakdown frequency, VFD faults, emergency interventions, standby availability and CBM compliance.

4. Energy Saving

The installed motor capacity is reduced from 450 kW to 120 kW, representing a 73.3% reduction in installed

motor capacity. This should not, however, be reported as a 73.3% measured energy saving. Actual energy performance must be established through operating-load and energy-meter data.

The proposed VFD-based system continuously adjusts pump speed according to pressure demand. For centrifugal pumps, power approximately follows the cube of speed; consequently, reduced-speed operation can provide substantial energy reduction under suitable system conditions.

The recommended energy KPI is Specific Energy Consumption (SEC):

$$SEC = \text{Energy consumed (kWh)} / \text{Water pumped (m}^3\text{)}$$
Pre- and post-retrofit measurements of energy, flow, pressure, operating hours and motor/VFD loading should be used to quantify the actual saving.

5. Digitalization

The retrofit establishes a Digital Pump Management System:

Sensors + IE5 Motor + VFD → PLC/Controller → BMS/SCADA → Dashboard → Energy Analytics + Maintenance Alerts

This architecture provides real-time visibility of pump electrical and hydraulic performance, operating status, alarms and trends. It also creates the foundation for integration with a broader institutional utility-management platform.

Digital data can therefore be used not only for monitoring but also for performance benchmarking, early fault detection, energy analysis, maintenance planning and management decision-making.

6. Integrated Outcome

The project transforms a 450 kW conventional fixed-speed pumping system into a 120 kW smart pumping system with three mutually reinforcing layers:

RELIABILITY

Continuous monitoring → Early abnormality detection → CBM → Planned intervention → Improved availability

ENERGY SAVING

IE5 motors → VFD control → Demand-based operation → Reduced unnecessary pumping → Verified SEC reduction

DIGITIZATION

Sensors → PLC → BMS/SCADA → Dashboard → Analytics → Data-driven utility management

7. Case Study Significance

The key value of the retrofit is not simply the replacement of pumps or motors. It demonstrates an integrated utility-management approach in which reliability, energy efficiency and digitalization are developed together. The system moves from manual operation and breakdown response toward intelligent, measurable and condition-based utility management. Performance validation: Actual energy savings should be established through pre- and post-implementation metering of kWh, flow, pressure, operating hours and motor/VFD loading.

A. Central Utility Monitoring and Control

The second case study covers substation SCADA, water-pumping automation, remote electricity and water metering, DG monitoring, HVAC monitoring and common-area lighting automation. The intended outcomes are online monitoring, abnormality alerts, equipment history and a defensible basis for capacity planning and upgradation.


Data domain	Required observation	Management interpretation
Electrical	Feeders, substations, loading, events and alarms	Identify capacity constraints, abnormal conditions and outage patterns
Water	Meters, tank levels, pump status and flow	Correlate pumping demand with water delivery and leakage/overflow events
DG	Runtime, load, fuel/energy consumption and alarms	Reconcile operation and identify abnormal consumption
HVAC	Status, temperatures, energy and alarms	Identify abnormal energy and service-performance conditions
Maintenance	Alerts, work orders, closure and repeat failures	Determine whether monitoring is influencing maintenance outcomes

Table IX. Central monitoring data and management interpretation.


Again, the source material provides the scope and expected outcomes but not measured field results. Therefore, outage-detection improvement, restoration-time reduction, energy savings and availability improvement should be reported only after extracting comparable pre- and post-implementation data.

A tentative presentable monitoring system can be shown as follows.


1. Remote metering



3. SCADA for Substation Monitoring



CENTRAL UTILITY MONITORING SYSTEM (model)



X. PERFORMANCE INDICATORS

Domain	Indicator	Data source	Interpretive use
Reliability	Availability; MTBF; MTTR; SAIFI/SAIDI where applicable	SCADA event log + maintenance record	Quantify continuity and restoration performance
Maintenance	Planned/unplanned work ratio; schedule compliance; failures preceded by alerts	Work orders + alert log	Measure maintenance maturity and predictive value
Digitization	Critical assets monitored online; data availability; alarm-to-action ratio	Monitoring platform	Measure useful digital adoption
Energy	Specific kWh/m ² ; kWh/unit volume; verified savings	Remote metering	Normalize and verify energy performance
Renewable	Renewable share; solar performance ratio; storage utilization	Generation metering + energy accounts	Measure renewable contribution and utilization
Planning	Risk-ranked renewal backlog; capacity headroom	Asset/EAM + load history	Prioritize CAPEX and capacity augmentation

Table X. Integrated KPI structure.

The KPI set is intentionally compact. The central principle is that each indicator should be computable from data already generated by the management system. The source manuscript similarly emphasizes availability, MTBF/MTTR, maintenance ratios, digital coverage, specific energy consumption and renewable indicators.

VIII. DISCUSSION

The principal contribution of the consolidated model is integration rather than the introduction of an individual technology. SCADA, BMS, IoT, remote metering and analytics are enabling layers; their value

arises when their outputs influence maintenance, operations, energy optimization and capital planning. The quantitative information currently available in the source documents is intentionally limited to indicative energy-efficiency planning values. This is a methodological strength if the paper is positioned as an implementation framework: it avoids presenting unverified savings or reliability improvements as experimental results. The next stage is to replace the case-study data placeholders with measured campus records and to apply normalized measurement and verification.

The main implementation risks identified in the manuscripts are incomplete asset records, inconsistent naming, legacy equipment, communication failures, cybersecurity exposure, poor sensor calibration, inadequate ownership of maintenance actions and insufficient data governance. Digital systems should therefore include network segmentation, role-based access, controlled remote access, logging, backup/recovery and manual fallback for critical functions.

The model is also scalable. A smaller campus may begin with remote metering and a limited dashboard, whereas a large campus may require SCADA, BMS, IoT gateways, a historian, CMMS/EAM integration and advanced analytics. The underlying management architecture remains the same.

IX. LIMITATIONS

Three limitations are material. First, the numerical energy-saving and payback figures are indicative planning values and are not measured results. Second, renewable open-access arrangements depend on the regulatory and tariff environment applicable at the time and location of implementation. Third, the benefits of digitization depend on organizational capacity, alarm rationalization, data quality and the ability of operators and maintenance teams to act on information. These limitations are explicitly recognized in the source manuscript. A further limitation of the present consolidated paper is that the supplied case-study sections do not contain actual numerical baseline/post-implementation datasets. Consequently, the paper provides a validated

measurement framework but does not claim field-verified performance improvements.

X. CONCLUSION

This paper consolidates two closely related manuscripts into a single integrated utility management framework for large campuses. Reliability is treated as the central service objective, while monitoring, operations and maintenance, digitization, energy conservation, and lifecycle planning operate as a closed management loop.

The five-layer architecture connects field sensing to communication, supervisory platforms, analytics and strategic planning. The maintenance model progresses from breakdown maintenance through preventive and condition-based regimes to digitized intervention. The energy framework combines Awareness, Optimize and Generate, followed by renewable pathways including rooftop solar, open-access procurement and battery energy storage.

The supplied quantitative data support an indicative planning interpretation: LED conversion is associated with about 40% indicative saving and payback below four years, while BLDC ceiling fans are associated with about 55% indicative saving and payback below two years. These figures are not presented as measured campus results. The proposed case-study tables and KPI structure provide the required method for converting future field data into verified evidence.

The principal methodological conclusion is that utility digitization should be judged by the decisions it enables rather than by the number of sensors or dashboard points installed. When load, condition, energy, alarm, maintenance and asset-history data are connected to action and lifecycle planning, a campus can move from reactive utility management toward evidence-based reliability and resource management.

ACKNOWLEDGMENT

The conceptual structure of this manuscript was developed from the author's working framework on large-campus utility management, integrating reliability, monitoring, digitization, energy conservation, renewable energy, and strategic

planning. The supplied source document was used as the primary conceptual basis for the framework.

REFERENCES

- [1] *IEEE Recommended Practice for the Design of Reliable Industrial and Commercial Power Systems*, IEEE Std 493 (IEEE Gold Book). [IEEE](#)
- [2] *IEEE Guide for Electric Power Distribution Reliability Indices*, IEEE Std 1366. [IEEE](#)
- [3] *IEEE Recommended Practice for Monitoring Electric Power Quality*, IEEE Std 1159. [IEEE](#)
- [4] *IEEE Recommended Practice for the Maintenance of Industrial and Commercial Power Systems*, IEEE Std 3007.2. [IEEE](#)
- [5] International Organization for Standardization, ISO 55000:2024, *Asset management—Vocabulary, overview and principles*. [ISO](#)
- [6] International Organization for Standardization, ISO 55001:2024, *Asset management—Management systems—Requirements*. [ISO](#)
- [7] International Organization for Standardization, ISO 50001, *Energy management systems—Requirements with guidance for use*. [ISO](#)
- [8] International Electrotechnical Commission, IEC 61850, *Communication Networks and Systems for Power Utility Automation*. [IEC](#)
- [9] International Electrotechnical Commission, IEC 62443, *Security for Industrial Automation and Control Systems*. [IEC](#)
- [10] Somani et al., “BEMOSS: An agent platform to facilitate grid-interactive building operation with IoT devices,” *Proc. IEEE ISGT Asia*, 2015.
- [11] Y. Wang et al., “An iterative optimization and learning-based IoT system for energy management of connected buildings,” *IEEE Internet of Things Journal*, vol. 9, no. 21, pp. 21246–21259, Nov. 2022.